

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0610502	BURR DISTRICT ELEMENTARY SCHOOL			NTNC	528	L	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
792 KILLINGWORTH RD AKA RTE 81							1	

Towns Served: HADDAM

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Asbestos (1094)		1 routine (RT) per nine years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/11 - 12/31/19		Complete
	1/1/20 - 12/31/28		
Total Coliform (3100)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	10/1/18 - 12/31/18		Complete
	1/1/19 - 3/31/19		Complete
	4/1/19 - 6/30/19		Complete
	7/1/19 - 9/30/19		
Lead And Copper (PBCU)		20 routine (RT) per six months	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/18 - 12/31/18		Complete
	1/1/19 - 6/30/19		Complete
	7/1/19 - 12/31/19		
Physical Parameters (PPS)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	10/1/18 - 12/31/18		Complete
	1/1/19 - 3/31/19		Complete
	4/1/19 - 6/30/19		Complete
	7/1/19 - 9/30/19		
Water Quality Parameters (WQPD)		4 routine (RT) per six months	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/18 - 12/31/18		Complete
Water System Facility: ENTRY POINT (WSF ID: 00700)			
Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Nitrate And Nitrite (NOX)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		
Lead And Copper (PBCU)		1 routine (RT) per six months	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/19 - 6/30/19		Complete
Pesticides, Herbicides and PCBs - Phase II & V (SOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0610502	BURR DISTRICT ELEMENTARY SCHOOL			NTNC	528	L	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
792 KILLINGWORTH RD AKA RTE 81							1	

Towns Served: HADDAM

Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

Pesticides, Herbicides and PCBs - Phase II & V (SOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/20 - 12/31/22		
Organic Chemicals (VOCS)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		
Water Quality Parameters - Basic (WQP1)		2 routine (RT) per six months	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	7/1/18 - 12/31/18		Complete

Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: ENTRY POINT (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
Orthophosphate	Entry Point Phosphate Monitoring (PHOS)	Minimum: 2.5 MG/L	2	
Start Date: 1/1/2017	Compliance History:	Operating Limit	Monitoring	
	Monitoring Period	Compliance Status:	Compliance Status:	
	11/1/2018 - 11/30/2018		N	
	12/1/2018 - 12/31/2018		N	
	1/1/2019 - 1/31/2019		N	
	2/1/2019 - 2/28/2019		N	
	3/1/2019 - 3/31/2019			
	4/1/2019 - 4/30/2019			
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
Orthophosphate	Entry Point Phosphate Monitoring (PHOS)	Maximum: 4.5 MG/L	2	
Start Date: 1/1/2017	Compliance History:	Operating Limit	Monitoring	
	Monitoring Period	Compliance Status:	Compliance Status:	
	11/1/2018 - 11/30/2018		N	
	12/1/2018 - 12/31/2018		N	
	1/1/2019 - 1/31/2019		N	
	2/1/2019 - 2/28/2019		N	
	3/1/2019 - 3/31/2019			
	4/1/2019 - 4/30/2019			
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
pH	Entry Point pH Monitoring (PHRD)	Minimum: 8.0 PH	Daily	
Start Date: 12/1/2014	Compliance History:	Operating Limit	Monitoring	
	Monitoring Period	Compliance Status:	Compliance Status:	
	11/1/2018 - 11/30/2018		N	
	12/1/2018 - 12/31/2018		N	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0610502	BURR DISTRICT ELEMENTARY SCHOOL			NTNC	528	L	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
792 KILLINGWORTH RD AKA RTE 81							1	

Towns Served: HADDAM

Water System Facility: ENTRY POINT (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 8.0 PH	Daily
Start Date: 12/1/2014			
	Compliance History: Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:
	1/1/2019 - 1/31/2019		N
	2/1/2019 - 2/28/2019		N
	3/1/2019 - 3/31/2019		
	4/1/2019 - 4/30/2019		
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Maximum: 9.7 PH	Daily
Start Date: 12/1/2014			
	Compliance History: Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:
	11/1/2018 - 11/30/2018		N
	12/1/2018 - 12/31/2018		N
	1/1/2019 - 1/31/2019		N
	2/1/2019 - 2/28/2019		N
	3/1/2019 - 3/31/2019		
	4/1/2019 - 4/30/2019		

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
LEAD PUBLIC EDUCATION CONSUMER DELIVERY	3/1/2019	12/6/2018
LEAD PUBLIC EDUCATION REPORT TO STATE	3/10/2019	1/30/2019
SWTS 1: PWS TO RECOMMEND SOWT	4/26/2019	
CCTS 1: PWS TO RECOMMEND OCCT	4/26/2019	
SWTS 2: DWS REVIEW & APPROVAL OF SOWT	12/31/2019	
CCTS 2: DWS REVIEW & APPROVAL OF OCCT	12/31/2020	
CROSS CONNECTION SURVEY REPORT	3/1/2024	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		ART 1	ART ROOM SINK	A		2	Y	Y
		BOYS BATH 1	BOYS BATHROOM #1	A	Y	2	Y	Y
		BOYS BATH 2	DISTRIBUTION SYSTEM	A	Y	2	Y	Y
		CUS 1	CUSTODIAN AREA	A		2	Y	Y
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		KIND 1	KINDERGART RM SINK	A	Y	2	Y	Y
		KIT 1	KITCHEN SINK	A	Y	2	Y	Y
		KIT HAND	KITCHEN HAND SINK	A	Y	2	Y	Y
		LIB 1	LIBRARY SINK	A	Y	2	Y	Y

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0610502	BURR DISTRICT ELEMENTARY SCHOOL			NTNC	528	L	GW	
Local Address (where applicable)			Service	Residential	Commercial	Industrial	Combined	Agricultural
792 KILLINGWORTH RD AKA RTE 81			Connections				1	

Towns Served: HADDAM

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		NURSE 1	NURSES SINK	A	Y	2	Y	Y
		PRE K B	PREKINDERGARTEN B	A	Y	2	Y	Y
		RM 1	ROOM 1 SINK	A	Y	2	Y	Y
		RM 10	ROOM 10 SINK	A	Y	2	Y	Y
		RM 11	ROOM 11 SINK	A	Y	2	Y	Y
		RM 13	ROOM 13	A	Y	2	Y	Y
		RM 15	ROOM 15 SINK	A	Y	2	Y	Y
		RM 15B	ROOM 15B SINK	I		2	Y	Y
		RM 16	ROOM 16 SINK	A	Y	2	Y	Y
		RM 17	ROOM 17 SINK	A	Y	2	Y	Y
		RM 18	ROOM 18 SINK	A	Y	2	Y	Y
		RM 3	ROOM 3 SINK	A	Y	2	Y	Y
		RM 6	ROOM 6 SINK	A	Y	2	Y	Y
		RM 8	ROOM 8 SINK	A	Y	2	Y	Y
		RM 9	ROOM 9 SINK	A	Y	2	Y	Y
		RM 9C	ROOM 9C SINK	I		2	Y	Y
		TEACH 1	TEACHERS ROOM SINK	A	Y	2	Y	Y
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
10281	WELL #1	2	WELL #1	A				
46390	BURR DISTRICT TREATMENT STATION							
52577	WELL #2	2	WELL #2	A				
53589	ATMOSPHERIC STORAGE							

Certified Operator Information

Water System Facility: **BURR DISTRICT TREATMENT STATION (WSF ID: 46390)**

Facility Classification: CLASS 2 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
ROWLEY, BRENDAN	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	12/31/2019
		WATER TREATMENT PLANT OPERATOR - CLASS II	12/31/2019

Contact Information

Name		Organization		Job Title	
Mr. Howard Thiery		Regional School District #17		Superintendent	
Mailing Address Line One		Mailing Address Line Two		City	State Zip Code
57 Little City Road				Higganum	CT 06441-0568
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address
860-345-4534		860-345-2817		860-790-1363	hthiery@rsd17.org

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0610502	BURR DISTRICT ELEMENTARY SCHOOL			NTNC	528	L	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
792 KILLINGWORTH RD AKA RTE 81						1	

Towns Served: HADDAM

Contact Role(s): **Administrative Contact, Legal Contact**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0610512	HADDAM ELEMENTARY SCHOOL			NTNC	350	L	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
272 ROUTE 154						1	

Towns Served: HADDAM

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Asbestos (1094)		1 routine (RT) per nine years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/11 - 12/31/19		Complete
	1/1/20 - 12/31/28		
Total Coliform (3100)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	10/1/18 - 12/31/18		Complete
	1/1/19 - 3/31/19		Complete
	4/1/19 - 6/30/19		
	7/1/19 - 9/30/19		
Lead And Copper (PBCU)		10 routine (RT) per six months	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/18 - 12/31/18		Complete
	1/1/19 - 6/30/19		
	7/1/19 - 12/31/19		
Physical Parameters (PPS)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	10/1/18 - 12/31/18		Complete
	1/1/19 - 3/31/19		Complete
	4/1/19 - 6/30/19		
	7/1/19 - 9/30/19		
Water System Facility: ENTRY POINT (WSF ID: 00700)			
Di(2-Ethylhexyl) - Phthalate (2039)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	10/1/18 - 12/31/18		Complete
	1/1/19 - 3/31/19		Complete
	4/1/19 - 6/30/19		
	7/1/19 - 9/30/19		
Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Nitrate And Nitrite (NOX)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		
Pesticides, Herbicides and PCBs-Phase II (SOC2)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0610512	HADDAM ELEMENTARY SCHOOL			NTNC	350	L	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
272 ROUTE 154						1	
Towns Served: HADDAM							

Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)							
Pesticides, Herbicides and PCBs-Phase II (SOC2)				1 routine (RT) per three years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>				
	1/1/20 - 12/31/22						
Pesticides, Herbicides and PCBs-Phase V (SOC5)				1 routine (RT) per three years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>				
ENTRY POINT (3)	1/1/17 - 12/31/19						
	1/1/20 - 12/31/22						
Organic Chemicals (VOCS)				1 routine (RT) per year			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>				
ENTRY POINT (3)	1/1/18 - 12/31/18		Complete				
	1/1/19 - 12/31/19		Complete				
	1/1/20 - 12/31/20						

Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: ENTRY POINT (WSFID: 00700)							
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month				
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.3 PH	4				
Start Date: 2/1/2018	Compliance History:	Operating Limit	Monitoring				
	Monitoring Period	Compliance Status:	Compliance Status:				
	11/1/2018 - 11/30/2018		N				
	12/1/2018 - 12/31/2018		N				
	1/1/2019 - 1/31/2019		N				
	2/1/2019 - 2/28/2019		N				
	3/1/2019 - 3/31/2019						
	4/1/2019 - 4/30/2019						
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month				
pH	Entry Point pH Monitoring (PHRD)	Maximum: 7.9 PH	4				
Start Date: 2/1/2018	Compliance History:	Operating Limit	Monitoring				
	Monitoring Period	Compliance Status:	Compliance Status:				
	11/1/2018 - 11/30/2018		N				
	12/1/2018 - 12/31/2018		N				
	1/1/2019 - 1/31/2019		N				
	2/1/2019 - 2/28/2019		N				
	3/1/2019 - 3/31/2019						
	4/1/2019 - 4/30/2019						

Other Compliance Schedules

<i>Compliance Schedule Activity</i>	<i>Due Date</i>	<i>Achieved Date</i>
CROSS CONNECTION EXEMPTION	3/1/2022	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0610512	HADDAM ELEMENTARY SCHOOL			NTNC	350	L	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
272 ROUTE 154							1	

Towns Served: HADDAM

Public Notification Requirements

Violation/Situation	Compliance Period	Notice Tier	Public Notification		PN Certification	
			Required	Performed	Due to DPH	Received
Physical Parameters M&R Violation	1/1/06 - 3/31/06	3	6/29/2007	10/18/2013	7/9/2007	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		ART 1	ART RM SINK 1	A	Y	2		
		ART 2	ART RM SINK 2	P	Y	2		
		ART 3	ART RM SINK 3	P	Y	2		
		BOY 1 FOUNT	BOYS LAV 1 FOUNTAIN	P	Y	2		
		BOY LAV 1-3	BOYS LAV 1 3RD SINK	P	Y	2		
		BOY LAV1-2	BOYS LAV 1 2ND SINK	P	Y	2		
		BOY LAV1-4	BOYS LAV 1 4TH SINK	P	Y	2		
		BOY LAV2-2	BOYS LAV 2 2ND SINK	P	Y	2		
		BOY LAV2-3	BOYS LAV 2 3RD SINK	P	Y	2		
		BOY LAV3-2	BOYS LAV 3 2ND SINK	P	Y	2		
		BOY LAV3-3	BOYS LAV 3 3RD SINK	P	Y	2		
		BOYS LAV 1	BOYS LAV 1 1ST SINK	A	Y	2		
		BOYS LAV 2	BOYS LAV 2 1ST SINK	A	Y	2		
		BOYS LAV 3	BOYS LAV 3 1ST SINK	P	Y	2		
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		FOUNT GYM	GYM WATER FOUNTAIN	P	Y	2		
		FOUNT KIT	KITCHEN WATER FOUNT	P	Y	2		
		FOUNT RM 6	WATER FOUNT NEAR RM	P	Y	2		
		FOUT NURSE	WATER FOUNT NEAR NUR	P	Y	2		
		GIRL LAV1-2	GIRLS LAV 1 2ND SINK	P	Y	2		
		GIRL LAV1-3	GIRLS LAV 1 3RD SINK	P	Y	2		
		GIRL LAV1-4	GIRLS LAV 1 4TH SINK	P	Y	2		
		GIRL LAV2-2	GIRLS LAV 2 2ND SINK	P	Y	2		
		GIRL LAV2-3	GIRLS LAV 2 3RD SINK	P	Y	2		
		GIRL LAV3-2	GIRLS LAV 3 2ND SINK	P	Y	2		
		GIRL LAV3-3	GIRLS LAV 3 3RD SINK	P	Y	2		
		GIRLS LAV 1	GIRLS LAV 1 1ST SINK	A	Y	2		
		GIRLS LAV 2	GIRLS LAV 2 1ST SINK	A	Y	2		
		GIRLS LAV 3	GIRLS LAV 3 1ST SINK	P	Y	2		
		HANDI BATH	HANDICAP BATH SINK	P	Y	2		
		KIT 1	KIT TAP 1 DOUB SINK	A	Y	2	Y	
		KIT 2	KIT TAP 2 DOUB SINK	P	Y	2		
		KIT 3	KIT TAP SINGLE SINK	P	Y	2		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0610512	HADDAM ELEMENTARY SCHOOL			NTNC	350	L	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
272 ROUTE 154						1	

Towns Served: HADDAM

Water System Facility and Sampling Point Inventory

<i>Water System</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
		KIT HAND	KITCHEN HAND SINK	P	Y	2		
		LIB	LIBRARY SINK	P	Y	2		
		MEN STAFF 1	MEN STF BATH SINK 1	P	Y	2		
		MEN STAFF 2	MEN STF BATH SINK 2	P	Y	2		
		MUSIC 1	MUSIC ROOM SINK	A	Y	2		
		NURSE 1	NURSE RM SINK	P	Y	2		
		NURSE 2	NURSE BATH SINK	P	Y	2		
		OFFICE 1	OFFICE RM SINK	P	Y	2		
		PROF RES	PROF RES RM SINK	P	Y	2		
		PSY BATH	PSY RM BATH SINK	P	Y	2		
		RM 1	ROOM 1 SINK	A	Y	2		
		RM 1 BATH	RM 1 BATHROOM SINK	P	Y	2		
		RM 10	ROOM 10 SINK	A	Y	2		
		RM 11	ROOM 11 SINK	A	Y	3		
		RM 12	ROOM 12 SINK	A	Y	2		
		RM 13	ROOM 13 SINK	A	Y	2		
		RM 14	ROOM 14 SINK	A	Y	2		
		RM 15	ROOM 15 SINK	A	Y	2		
		RM 19	ROOM 19 SINK	A	Y	2		
		RM 2	ROOM 2 SINK	A	Y	2		
		RM 3	ROOM 3 SINK	A	Y	2		
		RM 4	ROOM 4 SINK	I		2		
		RM 5	ROOM 5 SINK	I	Y	2		
		RM 6	ROOM 6 SINK	A	Y	2		
		RM 7	ROOM 7 SINK	A	Y	2		
		RM 8	ROOM 8 SINK	A	Y	2		
		RM 9	ROOM 9 SINK	A	Y	2		
		SERV KIT	SERVICE KITCHEN SINK	P	Y	2		
		SPEECH	SPEECH RM SINK	P	Y	2		
		STAFF 1	STAFF RM SINK 1	A	Y	2		
		STAFF 2	STAFF RM SINK 2	P	Y	2		
		UNISEX 2	UNISEX BATH 2ND FL	P	Y	2		
		UNISEX1	UNISEX BATH 1ST FL	P	Y	2		
		UPSTREAM	WITHIN 5 SERVICE CON	A				
		WOM STAFF 1	WOM STF BATH SINK 1	P	Y	2		
		WOM STAFF 2	WOM STF BATH SINK 2	P	Y	2		
00700	ENTRY POINT	3	ENTRY POINT	A				
10282	WELL 1	2	WELL	A				

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0610512	HADDAM ELEMENTARY SCHOOL			NTNC	350	L	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
272 ROUTE 154						1	
Towns Served: HADDAM							

Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
46392	HADDAM ELEMENTARY TREATMENT STATION							
51144	WELL 2	2	WELL 2	A				
51146	ATMOSPHERIC TANK							
51148	PUMP STATION							

Certified Operator Information

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)								
Facility Classification: SMALL WATER SYSTEM								
<i>Operator Name</i>	<i>Operator Type</i>	<i>Certification(s)</i>	<i>Certification Expiration</i>					
ROWLEY, BRENDAN	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	12/31/2019					
		WATER TREATMENT PLANT OPERATOR - CLASS II	12/31/2019					

Contact Information

Name				Organization			Job Title		
Mr. Howard Thiery				Regional School District #17			Superintendent		
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
57 Little City Road						Higganum		CT	06441-0568
Business Phone		Extension	Fax		Mobile Phone	Emergency Phone	Email Address		
860-345-4534			860-345-2817			860-790-1363	hthiery@rsd17.org		
Contact Role(s): Administrative Contact, Legal Contact									

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0610563	HADDAM-KILLINGWORTH HIGH SCHOOL			NTNC	850	L	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
LITTLE CITY ROAD				1				

Towns Served: HADDAM

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Asbestos (1094)		1 routine (RT) per nine years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/11 - 12/31/19		Complete
	1/1/20 - 12/31/28		
Total Coliform (3100)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	11/1/18 - 11/30/18		Complete
	12/1/18 - 12/31/18		Complete
	1/1/19 - 1/31/19		Complete
	2/1/19 - 2/28/19		Complete
	3/1/19 - 3/31/19		Complete
	4/1/19 - 4/30/19		
	5/1/19 - 5/31/19		
	6/1/19 - 6/30/19		
	7/1/19 - 7/31/19		
	8/1/19 - 8/31/19		
	9/1/19 - 9/30/19		
	10/1/19 - 10/31/19		
Lead And Copper (PBCU)		10 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/18 - 12/31/20	6/1-9/30	
	1/1/21 - 12/31/23	6/1-9/30	
Physical Parameters (PPS)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	11/1/18 - 11/30/18		Complete
	12/1/18 - 12/31/18		Complete
	1/1/19 - 1/31/19		Complete
	2/1/19 - 2/28/19		Complete
	3/1/19 - 3/31/19		Complete
	4/1/19 - 4/30/19		
	5/1/19 - 5/31/19		
	6/1/19 - 6/30/19		
	7/1/19 - 7/31/19		
	8/1/19 - 8/31/19		
	9/1/19 - 9/30/19		
	10/1/19 - 10/31/19		
Water System Facility: ENTRY POINT (WSF ID: 00700)		1 routine (RT) per three years	
Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0610563	HADDAM-KILLINGWORTH HIGH SCHOOL			NTNC	850	L	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
LITTLE CITY ROAD			1				
Towns Served: HADDAM							

Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
	1/1/20 - 12/31/22		
Nitrate And Nitrite (NOX)		1 routine (RT) per year	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		
Pesticides, Herbicides and PCBs - Phase II & V (SOCS)		1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Organic Chemicals (VOCS)		1 routine (RT) per year	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		

Water System Facility: WELL 1 (WSF ID: 10284)

E. Coli (3014)		1 triggered (TG) per period	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
WELL 1 (2)	10/15/18 - 10/21/18		Complete

Water System Facility: WELL 2 (WSF ID: 56372)

E. Coli (3014)		1 triggered (TG) per period	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
WELL 2 (2)	10/15/18 - 10/21/18		Complete

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
CROSS CONNECTION SURVEY REPORT	3/1/2024	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		BB OFFICE	BOY BATH NEAR OFF	A	Y	N		
		BB116	BOY BATH NEAR C116	A	Y	N		
		BOIL1	BOILER ROOM SINK	A	Y	2		
		CUSCL101	CUSTOD CLOSET SINK	A	Y	2		
		CUSCL201	CUSTOD CLOSET SINK	A	Y	2		
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0610563	HADDAM-KILLINGWORTH HIGH SCHOOL			NTNC	850	L	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
LITTLE CITY ROAD				1				

Towns Served: HADDAM

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		FAC1	FACULTY LOUNGE SINK	A	Y	2		
		GB OFFICE	GIRL BATH NEAR OFF	A	Y	N		
		GB114	GIRL BATH NEAR C114	A	Y	N		
		HSBLR1	HS BOYS LOCKER SINK	A	Y	2		
		HSGLR1	HS GIRLS LOCKER SINK	A	Y	2		
		KIT 1	KIT SINK	A	Y			
		KIT1	KITCHEN SINK ASBEST	A	Y	2		
		MB102	MEN BATH NEAR C102	A	Y	N		
		MB112	MEN BATH NEAR C112	A	Y	N		
		MB131	MEN BATH NEAR 131	A	Y	N		
		MB202	MEN BATH NEAR C202	A	Y	N		
		MB212	MEN BATH NEAR C212	A	Y	N		
		MB216	MEN BATH NEAR C216	A	Y	N		
		MB-B202	MEN BATH NEAR B202	A	Y	N		
		MBTV1	MEN BATH TV RM 1ST	A	Y	N		
		MBTV2	MEN BATH TV RM 2ND	A	Y	N		
		MCBF1	MEDIA CENT BOT FLOOR	A	Y	2		
		MCTF1	MEDIA CENT TOP FLOOR	A	Y	2		
		MSLR1	MID SCH LOCK RM SINK	A	Y	2		
		MSLR2	MID SCH LOCK RM SINK	A	Y	2		
		OFFMS	OFFICE MID SCH SINK	A	Y	2		
		UPSTREAM	WITHIN 5 SERVICE CON	A				
		WB102	WOM BATH NEAR C102	A	Y	N		
		WB114	WOM BATH NEAR C114	A	Y	N		
		WB131	WOM BATH NEAR 131	A	Y	N		
		WB202	WOM BATH NEAR C202	A	Y	N		
		WB214	WOM BATH NEAR C214	A	Y	N		
		WB-B202	WOM BATH NEAR B202	A	Y	N		
		WBTV1	WOM BATH TV RM 1SR	A	Y	N		
		WBTV2	WOM BATH TV RM 2ND	A	Y	N		
00700	ENTRY POINT	3	ENTRY POINT	A				
10284	WELL 1	2	WELL 1	A				
54653	HYDROPNEUMATIC TANK							
54655	ATMOSPHERIC TANK							
56372	WELL 2	2	WELL 2	A				

Certified Operator Information

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0610563	HADDAM-KILLINGWORTH HIGH SCHOOL			NTNC	850	L	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
LITTLE CITY ROAD			1				

Towns Served: HADDAM

Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Facility Classification: SMALL WATER SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
ROWLEY, BRENDAN	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	12/31/2019
		WATER TREATMENT PLANT OPERATOR - CLASS II	12/31/2019

Contact Information

Name		Organization		Job Title		
Mr. Howard Thiery		Regional School District #17		Superintendent		
Mailing Address Line One		Mailing Address Line Two		City	State	Zip Code
57 Little City Road				Higganum	CT	06441-0568
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
860-345-4534		860-345-2817		860-790-1363	hthiery@rsd17.org	

Contact Role(s): **Administrative Contact, Legal Contact**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0610593	YOUNG HORIZONS DAYCARE			NTNC	60	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
120 SAYBROOK ROAD				1				

Towns Served: HADDAM

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Asbestos (1094)		1 routine (RT) per nine years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/11 - 12/31/19		
	1/1/20 - 12/31/28		
Total Coliform (3100)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	10/1/18 - 12/31/18		Complete
	1/1/19 - 3/31/19		Complete
	4/1/19 - 6/30/19		Complete
	7/1/19 - 9/30/19		
Lead And Copper (PBCU)		5 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/18 - 12/31/20	6/1-9/30	
	1/1/21 - 12/31/23	6/1-9/30	
Physical Parameters (PPS)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	10/1/18 - 12/31/18		Complete
	1/1/19 - 3/31/19		Complete
	4/1/19 - 6/30/19		Complete
	7/1/19 - 9/30/19		
Water System Facility: ENTRY POINT (WSF ID: 00700)			
Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Nitrate And Nitrite (NOX)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		
	1/1/20 - 12/31/20		
Pesticides, Herbicides and PCBs - Phase II & V (SOCS)		1 (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19	1/1-12/31	Waiver
Pesticides, Herbicides and PCBs - Phase II & V (SOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Organic Chemicals (VOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/18 - 12/31/20		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0610593	YOUNG HORIZONS DAYCARE			NTNC	60	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
120 SAYBROOK ROAD				1				
Towns Served: HADDAM								

Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

Organic Chemicals (VOCS)

1 routine (RT) per three years

Sampling Point (Sampling Point ID)

Monitoring Period

Collection Period

Compliance Status

1/1/21 - 12/31/23

Other Compliance Schedules

Compliance Schedule Activity

Due Date

Achieved Date

CROSS CONNECTION EXEMPTION

3/1/2022

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	GENERIC DISTRIBUTION	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
		YH001	UPSTAIRS KITCHEN	A	Y	N	Y	
		YH002	UPSTAIRS BATHROOM	A	Y	N		
		YH003	DOWNSTAIRS KITCHEN	A	Y	N		
		YH004	DOWNSTAIRS BATH	A	Y	N		
		YH005	DOWNSTAIRS CRAFT	A	Y	N		
		YH006	UPSTAIRS INFANT	P	Y	N		
		YH007	UPSTAIRS TODDLER	P	Y	N		
		YH008	3RD FL BATHRM	P	Y	N		
00700	ENTRY POINT	3	ENTRY POINT	A				
10285	WELL	2	WELL	A				

Certified Operator Information

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Facility Classification: SMALL WATER SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
RADICCHI, PAUL J.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2021
		WATER TREATMENT PLANT OPERATOR - CLASS II	12/31/2020

Contact Information

Name				Organization			Job Title		
Ms. Susan Dering				Young Horizons Daycare Center			Owner/Operator		
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
120 Saybrook Road						Higganum		CT	06441
Business Phone	Extension	Fax		Mobile Phone	Emergency Phone	Email Address			
860-345-4347					860-345-8337				
Contact Role(s):	Owner								

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0610593	YOUNG HORIZONS DAYCARE			NTNC	60	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
120 SAYBROOK ROAD			1				

Towns Served: HADDAM

Name				Organization			Job Title		
Mr. Todd M Peterson				Young Horizons Day Care			Owner		
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
120 Saybrook Rd						Haddam		CT	06441
Business Phone		Extension	Fax	Mobile Phone		Emergency Phone	Email Address		

Contact Role(s): **Legal Contact, Owner**

Name				Organization			Job Title		
Ms. Dianna P Peterson				Young Horizons Day Care					
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
120 Saybrook Rd						Haddam		CT	06438
Business Phone		Extension	Fax		Mobile Phone	Emergency Phone	Email Address		

Contact Role(s): **Legal Contact, Owner**

Name				Organization			Job Title		
Ms. Michelle Johnson				Young Horizons Day Care Center			Manager		
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
120 Saybrook Road						Haddam		CT	06424
Business Phone		Extension	Fax		Mobile Phone	Emergency Phone	Email Address		
860-345-4347						860-685-1992	younghorizonsdaycare@gmail.com		

Contact Role(s): **Administrative Contact**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0610154	FIRST CONGREGATIONAL CHURCH OF HADDAM			NTNC	61	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
905 SAYBROOK ROAD				1			
Towns Served: HADDAM							

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Asbestos (1094) 1 routine (RT) per nine years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/11 - 12/31/19		
	1/1/20 - 12/31/28		

Total Coliform (3100) 1 routine (RT) per quarter

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	10/1/18 - 12/31/18		Complete
	1/1/19 - 3/31/19		Complete
	4/1/19 - 6/30/19		
	7/1/19 - 9/30/19		

Lead And Copper (PBCU) 5 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/16 - 12/31/18	6/1-9/30	Complete
	1/1/19 - 12/31/21	6/1-9/30	
	1/1/22 - 12/31/24	6/1-9/30	

Physical Parameters (PPS) 1 routine (RT) per quarter

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	10/1/18 - 12/31/18		Complete
	1/1/19 - 3/31/19		Complete
	4/1/19 - 6/30/19		
	7/1/19 - 9/30/19		

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

Inorganic Chemicals (IOCS) 1 routine (RT) per year

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		
	1/1/20 - 12/31/20		

Nitrate And Nitrite (NOX) 1 routine (RT) per year

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		

Pesticides, Herbicides and PCBs-Phase II (SOC2) 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

Pesticides, Herbicides and PCBs-Phase V (SOC5) 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0610154	FIRST CONGREGATIONAL CHURCH OF HADDAM			NTNC	61	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
905 SAYBROOK ROAD				1			
Towns Served: HADDAM							

Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

Organic Chemicals (VOCS)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		
	1/1/20 - 12/31/20		

Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: ENTRY POINT (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.0 PH	4
Start Date: 4/1/2016	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	11/1/2018 - 11/30/2018		N
	12/1/2018 - 12/31/2018		N
	1/1/2019 - 1/31/2019		N
	2/1/2019 - 2/28/2019		N
	3/1/2019 - 3/31/2019		
	4/1/2019 - 4/30/2019		

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
CROSS CONNECTION EXEMPTION	3/1/2015	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		FCCTAP	WS2612-2	A	Y			
		FCCTAP1	00600	A	Y			
		FCCTAP-1	KITCHEN SINK R	P	Y	1		
		FCCTAP2	00600	A	Y			
		FCCTAP-2	KITCHEN SINK L	P	Y	1		
		FCCTAP3	00600	A	Y			
		FCCTAP-3	DOWNSTAIRS MENS RM	P		1		
		FCCTAP4	00600	A	Y			
		FCCTAP-4	DOWNSTAIRS LADIES RM	P		1		
		FCCTAP5	00600	A	Y			
		FCCTAP-5	UPSTAIRS MENS RM	P		1		
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0610154	FIRST CONGREGATIONAL CHURCH OF HADDAM			NTNC	61	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
905 SAYBROOK ROAD				1			
Towns Served: HADDAM							

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
10966	WELL	2	WELL	A				
57378	TREATMENT STATION							

Certified Operator Information

Water System Facility: **TREATMENT STATION (WSF ID: 57378)**

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
O'SHAUGHNESSY, WILLIAM J.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2021

Contact Information

Name			Organization			Job Title		
Mr. Mark Soneson			First Cong. Church , Haddam			Property Committee		
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
P. O. Box 215						Haddam	CT	06438
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
860-250-0864					msoneson@sbcglobal.net			

Contact Role(s): **Administrative Contact, Legal Contact**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0610564	VILLAGE SHOPPING CENTER			NTNC	32	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
26 KILLINGWORTH ROAD				1			

Towns Served: HADDAM

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Asbestos (1094)		1 routine (RT) per nine years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/11 - 12/31/19		Complete
	1/1/20 - 12/31/28		
Total Coliform (3100)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	10/1/18 - 12/31/18		Complete
	1/1/19 - 3/31/19		Complete
	4/1/19 - 6/30/19		
	7/1/19 - 9/30/19		
Lead And Copper (PBCU)		5 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/18 - 12/31/18	6/1-9/30	Complete
	1/1/19 - 12/31/19	6/1-9/30	
	1/1/20 - 12/31/20	6/1-9/30	
Physical Parameters (PPS)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	10/1/18 - 12/31/18		Complete
	1/1/19 - 3/31/19		Complete
	4/1/19 - 6/30/19		
	7/1/19 - 9/30/19		

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
Nitrate And Nitrite (NOX)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		
Pesticides, Herbicides and PCBs - Phase II & V (SOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Organic Chemicals (VOCS)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	10/1/18 - 12/31/18		Complete
	1/1/19 - 3/31/19		Complete
	4/1/19 - 6/30/19		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0610564	VILLAGE SHOPPING CENTER			NTNC	32	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
26 KILLINGWORTH ROAD				1			
Towns Served: HADDAM							

Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)			
Organic Chemicals (VOCS)		1 routine (RT) per quarter	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
	7/1/19 - 9/30/19		

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
CROSS CONNECTION EXEMPTION	3/1/2016	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
21072	WELL	2	WELL	A				

Certified Operator Information

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)			
Facility Classification: SMALL WATER SYSTEM			Certification
Operator Name	Operator Type	Certification(s)	Expiration
BARRIS, DAVID C.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I	12/31/2020

Contact Information

Name			Organization			Job Title		
Ms. Anna Kanaras								
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
26 Killingworth Rd			PO Box 837			Higganum	CT	06441
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
860-345-8745					annakanaras@sbcglobal.net			

Contact Role(s): **Administrative Contact**

Name			Organization			Job Title		
Village Plaza LLC								
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
26 Killingworth Rd						Killingworth	CT	06419
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			

Contact Role(s): **Owner**

--	--	--	--	--	--	--	--	--

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0610564	VILLAGE SHOPPING CENTER	NTNC	32	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial
26 KILLINGWORTH ROAD				1	
Towns Served: HADDAM					
Name		Organization		Job Title	
Mr. John Kanaras		Village Plaza LLC		Member-Manager	
Mailing Address Line One		Mailing Address Line Two		City	State
114 Silver Spring Drive		P.O. Box 837		Higganum	CT
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address
Contact Role(s): Legal Contact					

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0614043	95 BRIDGE ROAD - HADDAM			NTNC	65	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				3			

Towns Served: HADDAM

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Asbestos (1094)		1 routine (RT) per nine years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/11 - 12/31/19		
	1/1/20 - 12/31/28		
Total Coliform (3100)		2 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	11/1/18 - 11/30/18		Complete
	12/1/18 - 12/31/18		Complete
	1/1/19 - 1/31/19		Complete
	2/1/19 - 2/28/19		Complete
	3/1/19 - 3/31/19		Complete
	4/1/19 - 4/30/19		Complete
	5/1/19 - 5/31/19		
	6/1/19 - 6/30/19		
	7/1/19 - 7/31/19		
	8/1/19 - 8/31/19		
	9/1/19 - 9/30/19		
	10/1/19 - 10/31/19		
Lead And Copper (PBCU)		5 routine (RT) per six months	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/18 - 12/31/18		Complete
	1/1/19 - 6/30/19		
	7/1/19 - 12/31/19		
Physical Parameters (PPS)		2 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	11/1/18 - 11/30/18		Complete
	12/1/18 - 12/31/18		Complete
	1/1/19 - 1/31/19		Complete
	2/1/19 - 2/28/19		Complete
	3/1/19 - 3/31/19		Complete
	4/1/19 - 4/30/19		Complete
	5/1/19 - 5/31/19		
	6/1/19 - 6/30/19		
	7/1/19 - 7/31/19		
	8/1/19 - 8/31/19		
	9/1/19 - 9/30/19		
	10/1/19 - 10/31/19		
Water System Facility: ENTRY POINT - BUILDING 1 (WSF ID: 00700)			
1,4-Dioxane (2049)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0614043	95 BRIDGE ROAD - HADDAM			NTNC	65	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				3			

Towns Served: HADDAM

Monitoring Requirements

Water System Facility: ENTRY POINT - BUILDING 1 (WSF ID: 00700)

1,4-Dioxane (2049)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	10/1/18 - 12/31/18		Complete
	1/1/19 - 3/31/19		Complete
	4/1/19 - 6/30/19		
	7/1/19 - 9/30/19		
Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Nitrate And Nitrite (NOX)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		
	1/1/20 - 12/31/20		
Pesticides, Herbicides and PCBs - Phase II & V (SOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Organic Chemicals (VOCS)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	10/1/18 - 12/31/18		Complete
	1/1/19 - 3/31/19		Complete
	4/1/19 - 6/30/19		
	7/1/19 - 9/30/19		

Water System Facility: ENTRY POINT - BUILDING 4 (WSF ID: 00701)

1,4-Dioxane (2049)		1 routine (RT) per quarter	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT - BUILDING 4 (3)	10/1/18 - 12/31/18		Complete
	1/1/19 - 3/31/19		Complete
	4/1/19 - 6/30/19		
	7/1/19 - 9/30/19		
Organic Chemicals (VOCS)		1 routine (RT) per quarter	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT - BUILDING 4 (3)	10/1/18 - 12/31/18		Complete
	1/1/19 - 3/31/19		Complete
	4/1/19 - 6/30/19		
	7/1/19 - 9/30/19		

Water System Facility: WELL # 1 (WSF ID: 55295)

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0614043	95 BRIDGE ROAD - HADDAM			NTNC	65	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				3			

Towns Served: HADDAM

Monitoring Requirements

Water System Facility: WELL # 1 (WSF ID: 55295)

Organic Chemicals (VOCS)		1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
WELL # 1 (2)	10/1/18 - 12/31/18		Complete	
	1/1/19 - 3/31/19		Complete	
	4/1/19 - 6/30/19			
	7/1/19 - 9/30/19			

Water System Facility: TREATMENT PLANT - BUILDING 1 (WSF ID: TP01)

Organic Chemicals (VOCS)		1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
BETWEEN GAC FILTERS (5)	10/1/18 - 12/31/18		Complete	
	1/1/19 - 3/31/19		Complete	
	4/1/19 - 6/30/19			
	7/1/19 - 9/30/19			

Water System Facility: TREATMENT PLANT - BUILDING 4 (WSF ID: TP04)

Organic Chemicals (VOCS)		1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
BETWEEN GAC FILTERS (5)	10/1/18 - 12/31/18		Complete	
	1/1/19 - 3/31/19		Complete	
	4/1/19 - 6/30/19			
	7/1/19 - 9/30/19			

Other Compliance Schedules

<i>Compliance Schedule Activity</i>	<i>Due Date</i>	<i>Achieved Date</i>
SWTS 1: PWS TO RECOMMEND SOWT	3/31/2016	
SWTS 2: DWS REVIEW & APPROVAL OF SOWT	9/30/2016	
CCTS 2: DWS REVIEW & APPROVAL OF OCCT	9/30/2017	
SUBMIT LEAD CONSUMER NOTICE CERTIFICATE	9/28/2018	
CROSS CONNECTION SURVEY REPORT	3/1/2019	

Public Notification Requirements

<i>Violation/Situation</i>	<i>Compliance Period</i>	<i>Notice Tier</i>	<i>Public Notification</i>		<i>PN Certification</i>	
			<i>Required</i>	<i>Performed</i>	<i>Due to DPH</i>	<i>Received</i>
E. Coli M&R Violation	2/19/18 - 2/25/18	3	5/24/2019		6/3/2019	
E. Coli M&R Violation	2/19/18 - 2/25/18	3	5/24/2019		6/3/2019	
E. Coli M&R Violation	2/19/18 - 2/25/18	3	5/24/2019		6/3/2019	
E. Coli M&R Violation	2/19/18 - 2/25/18	3	5/24/2019		6/3/2019	
E. Coli M&R Violation	1/17/18 - 1/23/18	3	5/24/2019		6/3/2019	
E. Coli M&R Violation	1/17/18 - 1/23/18		5/24/2019		6/3/2019	
E. Coli M&R Violation	1/17/18 - 1/23/18	3	5/24/2019		6/3/2019	
E. Coli M&R Violation	1/17/18 - 1/23/18	3	5/24/2019		6/3/2019	
E. Coli M&R Violation	1/17/18 - 1/23/18		5/24/2019		6/3/2019	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0614043	95 BRIDGE ROAD - HADDAM			NTNC	65	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				3			

Towns Served: HADDAM

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION	A				
		95BRD1DS	BLDG 1 KITCHEN	A	Y	2	Y	
		95BRD1MB	BLDG 1 MENS BATH	A	Y	2		
		95BRD1WB	BLDG 1 WOMENS BATH	A	Y	2		
		95BRD4B	BLDG 4 BATH	A	Y	2		
		95BRD4K	BLDG 4 KITCHEN	A	Y	2		
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT - BUILDING 1	3	ENTRY POINT	A				
00701	ENTRY POINT - BUILDING 4	3	ENTRY POINT - BUILDING 4	A				
55295	WELL # 1	2	WELL # 1	A				
TP01	TREATMENT PLANT - BUILDING 1	5	BETWEEN GAC FILTERS	A				
TP04	TREATMENT PLANT - BUILDING 4	5	BETWEEN GAC FILTERS	A				

Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Facility Classification: SMALL WATER SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
RADICCHI, PAUL J.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2021
		WATER TREATMENT PLANT OPERATOR - CLASS II	12/31/2020

Water System Facility: **TREATMENT PLANT - BUILDING 1 (WSF ID: TP01)**

Facility Classification:

Operator Name	Operator Type	Certification(s)	Certification Expiration
RADICCHI, PAUL J.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2021
		WATER TREATMENT PLANT OPERATOR - CLASS II	12/31/2020

Water System Facility: **TREATMENT PLANT - BUILDING 4 (WSF ID: TP04)**

Facility Classification:

Operator Name	Operator Type	Certification(s)	Certification Expiration
RADICCHI, PAUL J.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2021
		WATER TREATMENT PLANT OPERATOR - CLASS II	12/31/2020

Contact Information

Name				Organization			Job Title		
Mr. Jon Sibley				Bridge Street Associates			Owner		
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
98 Bridge Street						Haddam		CT	06438
Business Phone		Extension	Fax	Mobile Phone		Emergency Phone	Email Address		
860-345-4523							jon.sibley@sibley.com		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0614043	95 BRIDGE ROAD - HADDAM			NTNC	65	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				3			

Towns Served: HADDAM

Contact Role(s): **Administrative Contact, Legal Contact, Owner**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.